

Kitemark™ Certificate

This is to certify that:

Safequip (Pty) Ltd
1 Saxenburg Road
Blackheath
Cape Town
7579
South Africa

Holds Certificate Number:

KM 760750

In respect of:

SANS 1910 and SANS 1567

Portable refillable fire extinguishers & Portable rechargeable fire extinguishers - CO2 type extinguishers

The issues and right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Group South Africa (Pty) Ltd (the "Conditions"). All defined terms in this certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.



For and on behalf of BSI:

Theuns Kotze, Regional Director - META

First Issued: 2024-08-30

Latest Issue: 2024-08-30

Effective Date: 2024-08-30

Expiry Date: 2027-08-29

Page: 1 of 2

Kitemark™ Certificate

No. KM 760750

Description	Model No	Additional Info
1 Litre water-based fire extinguisher, stored pressure. Temperature range: + 5°C to + 60°C. Fire rating: 3A	LITH EX1-1	Top Level Drawing Number - 24701 Dated 01/02/2019
2 Litre water-based fire extinguisher, stored pressure. Temperature range: + 5°C to + 60°C. Fire rating: 5A	LITH EX2-2	Top Level Drawing Number - 24703 Dated 01/02/2019
6 Litre water-based fire extinguisher, stored pressure. Temperature range: + 5°C to + 60°C. Fire rating: 13A	LITH EX6-6	Top Level Drawing Number - 24712 Dated 01/02/2019
9 Litre water-based fire extinguisher, stored pressure. Temperature range: + 5°C to + 60°C. Fire rating: 13A	LITH EX9-9	Top Level Drawing Number - 24713 Dated 01/02/2019

Products Tested to SANS 1910:2022

First Issued: 2024-08-30

Latest Issue: 2024-08-30

Effective Date: 2024-08-30

Expiry Date: 2027-08-29

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Group South Africa (Pty) Ltd, Park Lane West, 194 Bancor Avenue, Waterkloof Glen X2, Pretoria, 0181, South Africa and should be returned immediately upon request.
To check its validity telephone +27 (0)12 004 0279. An electronic certificate can be authenticated [online](#).

BSI Group South Africa (Pty) Ltd, registered in South Africa under number 2011/110446/07, at Park Lane West, 194 Bancor Avenue, Waterkloof Glen X2, Pretoria, 0182, Republic of South Africa.
A member of BSI Group of Companies.